



Council of the
European Union

Brussels, 6 July 2017
(OR. en)

11069/17
ADD 1

ENER 321

COVER NOTE

From:	European Commission
date of receipt:	5 July 2017
To:	General Secretariat of the Council
No. Cion doc.:	D046135/02 - ANNEX 1
Subject:	ANNEX to the Commission Regulation (EU)... establishing a network code on electricity emergency and restoration - ANNEX

Delegations will find attached document D046135/02 - ANNEX 1.

Encl.: D046135/02 - ANNEX 1



EUROPEAN
COMMISSION

Brussels, **XXX**
D046135/02
[...](2017) **XXX** draft

ANNEX 1

ANNEX

to the

Commission Regulation (EU)../..

establishing a network code on electricity emergency and restoration

ANNEX

to the

Commission Regulation (EU)../..

establishing a network code on electricity emergency and restoration

ANNEX

Automatic low frequency demand disconnection scheme characteristics:

Parameter	Values SA Continental Europe	Values SA SA Nordic	Values SA SA Great Britain	Values SA SA Ireland	Measuring Unit
Demand disconnection starting mandatory level : Frequency	49	48.7 – 48.8	48.8	48.85	Hz
Demand disconnection starting mandatory level: Demand to be disconnected	5	5	5	6	% of the Total Load at national level
Demand disconnection final mandatory level: Frequency	48	48	48	48.5	Hz
Demand disconnection final mandatory level: Cumulative Demand to be disconnected	45	30	50	60	% of the Total Load at national level
Implementation range	±7	±10	±10	±7	% of the Total Load at national level, for a given Frequency
Minimum number of steps to reach the final mandatory level	6	2	4	6	Number of steps
Maximum Demand disconnection for each step	10	15	10	12	% of the Total Load at national level, for a given step